

NOTES

1. THE WELL FOR A CLASS A PUBLIC WATER SYSTEM NEEDS TO BE LOCATED AT LEAST 200 FEET FROM WASTEWATER TREATMENT AND DISPOSAL SYSTEMS, PIT PRIVIES, HOLDING TANKS, SEWER MANHOLES, LIFT STATIONS, CLEANOUTS, AND COMMUNITY SEWER LINES; AND 100 FEET FROM PETROLEUM LINES AND STORAGE TANKS.
2. COMMUNITY SEWER LINES ARE PROPOSED FOR INSTALLATION IN FIRST STREET AND D STREET RIGHTS-OF-WAY.




CITY OF ANDERSON CONCEPTUAL PLANNING AND BUSINESS PLAN			
MULTI-USE FACILITY SITE CONCEPTUAL PLAN			
JOB NO.	ANDE-ANDE-001-0001	DRAWN:	CEG
DATE:	SEPTEMBER 26, 2006	FILE:	FIGURES.dwg
			
			Figure 3

Figure 3